



WELLINGTON NORTH
SEMPER PORRO

**Township of Wellington North
SUPPLY AND APPLICATION OF ASPHALT
Request for Tender (RFT 2024-001)**

ADDENDUM NO. 1

This addendum has been issued to revise the tender package as follows:
The following questions have been received. Answers / Clarification follow each question:

Question 1:

With respect to the work on rural roads, will the Township be responsible for the necessary shouldering works?

Answer / Clarification 1:

The Township will be responsible for shoulder work.

Question 2:

With respect to driveway restorations, can the Township please provide an assumed offset from EP, that the Bidder will be required to tie-in existing asphalt driveways?

Answer / Clarification 2:

Limits of restoration of driveways will be determined at the time of construction. Bidders can assume that restoration limits are from EP to property line.

Question 3:

With respect to Part E, Item #1, can the Township please advise on the thickness of existing asphalt.

Answer / Clarification 3:

Existing thickness of asphalt is unknown at this time. It is assumed to range from 25mm – 75mm thickness. Tender item is to remove full depth asphalt in the lump sum item.

Question 4:

Based on section 3, scope of work, the Bidder is to be responsible for pulverizing and or removal of asphalt full depth in urban areas. Should PART D – Urban Area 1 – Page Street, include an item for said work? Or will this cost need to be covered under item #2 within this section.

Answer / Clarification 4:

Page Street is currently gravel surface. Therefore, asphalt removal is not required under Part D, Urban Area 1, Page Street.

This addendum shall form part of the contract documents. The Tenderer shall sign the addendum and shall submit this addendum in the same envelope as their tender. The tenderer shall acknowledge receipt of this tender on the Form of Tender.

Signature_____

Company_____