



Annual and Summary Report

For the Period of Jan. 1, 2025 to Dec. 31, 2025

For Arthur and Mount Forest Drinking Water Systems

Prepared By:

Sara McDougall, Process and Compliance Analyst
Environmental Services Department

Revision Date: January 30, 2026

Table of Contents

Introduction..... 1

Systems Overview..... 2

 Arthur Drinking Water System..... 2

 Mount Forest Drinking Water System..... 3

Summary Report..... 4

a) Incidents of Regulatory Non-Compliance..... 4

b) Adverse Water Quality Incidents..... 4

c) Summaries of Flow Rates and Water Supply Capacities 4

d) Raw and Treated Water Quality..... 8

e) Significant Expenses Incurred..... 22

f) Source Water Protection..... 22

List of Tables

Table 1: Arthur Well 7b Flows	5
Table 2: Arthur Well 8a Flows.....	5
Table 3: Arthur Well 8b Flows.....	6
Table 4: Mount Forest Well 3 Flows.....	6
Table 5: Mount Forest Well 4 Flows	7
Table 6: Mount Forest Well 5 Flows.....	7
Table 7: Mount Forest Well 6 Flows	8
Table 8: O. Regulation 170/03 Schedule 7-2, Distribution Free Chlorine Residual Summary.....	8
Table 9: O. Regulation 170/03 Schedule 7-3, Raw Turbidity Sampling Summary.....	9
Table 10: O. Regulation 170/03 Schedule 10-4, Raw Bacteriological Sampling Summary	9
Table 11: O. Regulation 170/03 Schedule 10-3, Treated Bacteriological Sampling Summary	9
Table 12: O. Regulation 170/03 Schedule 10-2, Distribution Sample Summary.....	10
Table 13: O. Regulation 170/03 Schedule 13-7, Nitrite and Nitrate Sampling Results Summary.....	11
Table 14: O. Regulation 170/03 Schedule 23 Results Arthur Well #7b	11
Table 15: O. Regulation 170/03 Schedule 23 Results Arthur Well #8	12
Table 16: O. Regulation 170/03 Schedule 23 Results Mount Forest Well #3	12
Table 17: O. Regulation 170/03 Schedule 23 Results Mount Forest Well #4.....	12
Table 18: O. Regulation 170/03 Schedule 23 Results Mount Forest Well #5	13
Table 19: O. Regulation 170/03 Schedule 23 Results Mount Forest Well #6	13
Table 20: O. Regulation 170/03 Schedule 24 Results for Arthur Well #7b	14
Table 21: O. Regulation 170/03 Schedule 24 Results for Arthur Well #8	15
Table 22: O. Regulation 170/03 Schedule 24 Results for Mount Forest Well #3	16
Table 23: O. Regulation 170/03 Schedule 24 Results for Mount Forest Well #4	17
Table 24: O. Regulation 170/03 Schedule 24 Results for Mount Forest Well #5	18
Table 25: O. Regulation 170/03 Schedule 24 Results for Mount Forest Well #6	19
Table 26: O. Regulation 170/03 Schedule 13-8 and 13-9, Fluoride and Sodium Results	20
Table 27: O. Regulation 170/03 Schedule 15.1, Lead, Alkalinity and pH Results.....	21

Introduction

Purpose

The purpose of this report is to provide information to several stakeholders and to satisfy the regulatory requirements of the Safe Drinking Water Act (SDWA), reporting required under Ontario Regulation 170/03 (Section 11 and Schedule 22). The report is a compilation of information that helps to demonstrate the ongoing provision of safe, consistent supply of high-quality drinking water to customers located within the Township of Wellington North (Arthur and Mount Forest).

Scope

This Annual and Summary report includes information from both Mount Forest and Arthur Drinking Water Systems for the period of January 1st to December 31st, 2025 (unless otherwise noted). The report is a collection of information that was previously found in two separate reports (Annual Report and Summary 22 Report to Council). The information is required to be reported to the following:

- the Drinking Water System Owners (Township of Wellington North Council);
- the public and customers

This report satisfies the requirements of both the Safe Drinking Water Act (SDWA) and Ontario Regulation 170/03:

-Section 11, Annual Reports which includes:

- a brief description of the drinking water systems;
- a list of water treatment chemicals used;
- a summary of the most recent water tests results required under O. Reg.170/03 or an approval, Municipal Drinking Water License (MDWL) or order;
- a summary of adverse test results and other issues reported to the Ministry including corrective action taken;
- a description of major expenses incurred to install, repair or replace required equipment;
- the location where this report is available for inspection/review.

And;

-Schedule 22, Summary Report which includes:

- list the requirements of the Safe Drinking Water Act, the Regulations, Drinking Water Works Permits (DWWP), Municipal Drinking Water License (MDWL), and any orders applicable to the system that were not met at any time during the period covered by the report;
- for each requirement that was not met, the duration of the failure and measures that were taken to correct the failure;
- a summary of the quantities and flow rates of the water supplied during the period covered by the report, including monthly average and maximum daily flows; and
- a comparison of this information to the rated capacity and flow rates approved in the system's approval, DWWP and/or MDWL.

This report satisfies applicable requirements for both the Arthur and Mount Forest Drinking Water Systems.

A copy of this report is available for viewing online at www.wellington-north.com

Inquiries can be made by emailing smcdougall@wellington-north.com or by calling 519-848-3620 x 4628

Notice

Please note that every reasonable effort is made to ensure the accuracy of this report. This report is published with the best available information at the time of the publication. In the event that errors or omissions occur, the online report will be updated. Please refer to the online version of the report for the most current version.

Systems Overview

The role of the water department is to provide customers and the community with safe, consistent supply of high-quality drinking water while meeting, exceeding, and continually improving on legal, operational, and quality management system requirements.

The Arthur and Mount Forest drinking water systems are Class II Water Distribution and Supply Subsystems, composed of groundwater wells and water distribution systems. From January 1st to December 31st, 2025, certified staff of three Operators, one Lead Hand, one Manager and one Process Compliance Analyst operated and maintained the systems.

The water department received full scope reaccreditation to the Drinking Water Quality Management Standard and continues to hold the accreditation after a successful off-site audit on August 15th, 2025 conducted by a third-party accreditation body. This full accreditation satisfies part of the requirements under the Municipal Drinking Water Licensing Program.

Arthur Drinking Water System

Arthur's municipal drinking water system provides water for a permanent population of approximately 2,628, comprised of approximately 1,261 residential connections and 111 Industrial/Commercial/Institutional (ICI) connections. ICI customers are fully metered and residential units are on a flat rate system. Arthur has approximately 21 km of water main.

The Arthur water system is comprised of three drilled wells, two pump houses, two elevated storage tanks and a water distribution system. The township uses 12% sodium hypochlorite for disinfection. Sodium silicate is used for iron sequestering at Well #7 and Waterworx is used at Well #8 for manganese sequestering. Each well is equipped with one well pump, discharge piping, and disinfection equipment. Well #8 is equipped with a back-up diesel generator. The system's supply for fire protection, peak demands and emergencies, is stored within two elevated storage tanks, one with a capacity of 1137 m³ and one with a capacity of 227m³.

The well pumps and associated metering pumps are started and stopped based on the water level in elevated tank number one. Once the low water level in the tank has been reached, the pump stations are called upon to supply the distribution system with the excess filling the elevated storage tanks to the normal top water level. This system is a demand/storage system. When the level drops below the lead pump start level, the lead well pump will start. If the level continues to drop, the next duty pump in sequence will start. All pumps stop at the normal top water level until the water level drops in elevated

tank number one and the pumps are required again. Whenever all pumps have stopped; the pump sequence changes. Pumps removed from service are automatically skipped.

From January 1st to December 31st, 2025, a total of 392,902.08 cubic meters of water was treated and pumped to the system. The average daily water demand was 1,075.74 cubic meters. The highest daily use of water occurred on August 7th, 2025 when 1,654.10 cubic meters of water was pumped.

Mount Forest Drinking Water System

Mount Forest's municipal drinking water system provides water for a permanent population of approximately 5,040, comprised of approximately 2,254 residential connections and 244 ICI connections. ICI customers are fully metered, and residential units are on a flat rate system. Mount Forest distribution system is approximately 37 km of water main.

The Mount Forest water system is comprised of four groundwater wells, four pump houses, a standpipe, and a water distribution system. The township uses 12% sodium hypochlorite for disinfection. Each well is equipped with one well pump, discharge piping, and disinfection equipment. Well #3 is equipped with a back-up diesel generator and a booster pump. The system's supply for fire protection, peak demands and emergencies, is stored within a 2083 m³ standpipe.

The well pumps and sodium hypochlorite metering pumps are started and stopped based on the standpipe water level. Once the low water level in the tank has been reached, the pump stations are called upon to supply the distribution system with the excess filling the standpipe to the normal top water level. This system is a demand/storage system. When the level drops below the lead pump start level, the lead well pump will start. If the level continues to drop, the first, second and third lag well pumps will be started, respectively. All pumps stop at the normal top water level until the water level drops in the standpipe and the pumps are required again. Whenever all pumps have stopped; the pump sequence changes. Pumps removed from service are automatically skipped.

From January 1st to December 31st, 2025, a total of 545,514.72 cubic meters of water was treated and pumped to the system. The average daily water demand was 1,493.27 cubic meters. The highest daily use of water occurred on July 6th, 2025 when 2,053.06 cubic meters of water was pumped.

Sampling and Testing

The Township of Wellington North's certified operators regularly test the water within the overall system including the raw water at the well source(s), after treatment, and within the distribution system. From January 1st to December 31st, 2025, all regulatory microbiological and chemical quality samples were taken by certified operators and tests performed by accredited, licensed laboratories on water samples collected throughout the drinking water system. These tests include regulatory testing, and those results are included in this report.

Arthur and Mount Forest drinking water systems are defined as large residential systems operated under the regulatory requirements of the Safe Drinking Water Act and the Ontario Water Resources Act (accessed at www.e-laws.gov.on.ca). The Arthur Drinking Water System is operated under Municipal Drinking Water License (MDWL) 113-101 and the Drinking Water Works Permit (DWWP) 113-201. The Mount Forest Drinking Water System is operated under MDWL 113-102 and DWWP 113-202.

The MDWL and the DWWP describe system-specific requirements that are supplementary to provincial regulations and act as a license for water supply and distribution operations. These documents outline

specific conditions and requirements regarding operation, maintenance and upgrades that are required by the system and are considered regulatory in nature. These documents are available by request for viewing at 160 Preston Street, Arthur.

Summary Report

a) Incidents of Regulatory Non-Compliance

This section describes all incidents of non-compliance (excluding those defined as “Adverse Water Quality Incidents” (AWQI) reported in Section B of this report). AWQI’s are required to be reported to the Ministry of Environment, Conservation & Parks (MECP) with respect to the following Acts and related regulations: Ontario Water Resources Act (OWRA), Safe Drinking Water Act (SDWA), the Environmental Protection Act (EPA), and Municipal Drinking Water Licenses (MDWL) and Drinking Water Works Permits (DWWP).

The most recent assessment of compliance for Arthur and Mount Forest Drinking Water Systems as determined by the MECP during the 2025 Annual Inspections resulted in a final inspection rating of 100% for each facility.

There was no non-compliance for either Arthur or Mount Forest Drinking Water Systems during the MECP inspections in 2025.

b) Adverse Water Quality Incidents

This section describes all “Adverse Water Quality Incidents” (AWQI). This term refers to any unusual test results from treated water that does not meet a provincial water quality standard, or situation where disinfection of the water may be compromised. An adverse water quality incident indicates that on at least one occasion, a water quality standard was not met.

There were no AWQI’s in 2025.

c) Summaries of Flow Rates and Water Supply Capacities

The Safe Drinking Water Act (SDWA) and the Ontario Water Resources Act (OWRA) each require that operating authority’s record and report water takings as governed by the Permits to Take Water (PTTW). The following tables list the quantities and flow rates of the water supplied during this reporting period, including monthly average and maximum daily flows, daily instantaneous peak flow rates and a comparison to the rated capacity and flow rates specified in the system approval:

Table 1: Arthur Well #7b Flows**Approved Volume (m3/day): 1961****Approved Flow Rate (L/sec): 22.7**

	Avg Daily Volume (m³)	% of Approved Volume	Max Daily Volume (m³)	% of Approved Volume	Peak Flow Rate (L/sec)	% of Approved Flow Rate
January	354.72	18.1	607.39	31.0	21.55	94.9
February	376.95	19.2	547.17	27.9	22.04	97.1
March	364.35	18.6	646.70	33.0	21.94	96.7
April	351.00	17.9	649.89	33.1	22.31	98.3
May	349.69	17.8	901.47	46.0	22.08	97.3
June	426.22	21.7	788.91	40.2	21.99	96.9
July	436.17	22.2	991.67	50.6	21.99	96.9
August	400.97	20.4	814.24	41.5	21.79	96.0
September	406.19	20.7	880.98	44.9	21.92	96.6
October	364.50	18.6	664.39	33.9	21.35	94.1
November	319.03	16.3	676.11	34.5	22.09	97.3
December	330.85	16.9	837.42	42.7	22.11	97.4

Table 2: Arthur Well #8a Flows**Approved Volume (m3/day): 2255****Approved Flow Rate (L/sec): 26.1**

	Avg Daily Volume (m³)	% of Approved Volume	Max Daily Volume (m³)	% of Approved Volume	Peak Flow Rate (L/sec)	% of Approved Flow Rate
January	352.88	15.6	611.28	27.1	24.89	95.4
February	319.62	14.2	601.08	26.7	25.07	96.1
March	310.39	13.8	561.28	24.9	24.88	95.3
April	307.81	13.7	581.51	25.8	24.68	94.6
May	357.35	15.8	620.83	27.5	25.27	96.8
June	390.24	17.3	734.35	32.6	24.96	95.6
July	427.27	18.9	592.97	26.3	25.30	96.9
August	429.62	19.1	913.85	40.5	25.19	96.5
September	291.86	12.9	640.67	28.4	25.66	98.3
October	328.77	14.6	462.01	20.5	24.66	94.5
November	361.32	16.0	650.50	28.8	25.99	99.6
December	343.33	15.2	638.71	28.3	24.66	94.5

Table 3: Arthur Well #8b Flows**Approved Volume (m3/day): 2255****Approved Flow Rate (L/sec): 26.1**

	Avg Daily Volume (m ³)	% of Approved Volume	Max Daily Volume (m ³)	% of Approved Volume	Peak Flow Rate (L/sec)	% of Approved Flow Rate
January	291.71	12.9	646.47	28.7	24.68	94.6
February	296.54	13.2	471.07	20.9	24.53	94.0
March	271.54	12.0	510.10	22.6	24.61	94.3
April	312.49	13.9	674.91	29.9	24.73	94.8
May	353.45	15.7	592.42	26.3	24.99	95.7
June	372.98	16.5	595.71	26.4	25.19	96.5
July	417.41	18.5	586.83	26.0	24.68	94.6
August	406.32	18.0	686.34	30.4	24.49	93.8
September	426.37	18.9	804.33	35.7	24.31	93.1
October	385.91	17.1	623.10	27.6	24.31	93.1
November	328.64	14.6	545.52	24.2	24.42	93.6
December	344.42	15.3	600.02	26.6	24.18	92.6

There was 392,902.08 m³ of water processed in Arthur for 2025 (Jan. 01 to Dec. 31). This represents 8.02 % increase compared to the same time period in 2024 and 3.64 % increase from 2023.

Table 4: Mount Forest Well #3 Flows**Approved Volume (m3/day): 1637****Approved Flow Rate (L/sec):22.7**

	Avg Daily Volume (m ³)	% of Approved Volume	Max Daily Volume (m ³)	% of Approved Volume	Peak Flow Rate (L/sec)	% of Approved Flow Rate
January	252.28	15.4	491.51	30.0	17.66	77.8
February	288.71	17.6	446.33	27.3	16.67	73.4
March	256.76	15.7	475.25	29.0	16.96	74.7
April	233.37	14.3	427.47	26.1	17.23	75.9
May	188.65	11.5	339.09	20.7	20.27	89.3
June	62.94	3.8	324.84	19.8	17.31	76.3
July	247.40	15.1	465.86	28.5	19.26	84.8
August	234.07	14.3	385.60	23.6	18.38	81.0
September	230.20	14.1	458.84	28.0	18.18	80.1
October	252.09	15.4	481.84	29.4	19.11	84.2
November	221.55	13.5	480.05	29.3	20.11	88.6
December	254.01	15.5	472.41	28.9	18.08	79.6

Table 5: Mount Forest Well #4 Flows**Approved Volume (m3/day): 1964****Approved Flow Rate (L/sec): 22.7**

	Avg Daily Volume (m³)	% of Approved Volume	Max Daily Volume (m³)	% of Approved Volume	Peak Flow Rate (L/sec)	% of Approved Flow Rate
January	346.57	17.6	621.05	31.6	18.68	82.3
February	306.43	15.6	544.29	27.7	18.53	81.6
March	379.01	19.3	764.67	38.9	18.42	81.1
April	329.15	16.8	619.83	31.6	18.6	81.9
May	316.73	16.1	530.54	27.0	18.55	81.7
June	312.03	15.9	575.38	29.3	18.22	80.3
July	302.47	15.4	717.60	36.5	18.31	80.7
August	301.39	15.3	614.50	31.3	18.38	81.0
September	306.39	15.6	550.74	28.0	18.23	80.3
October	354.44	18.0	733.43	37.3	18.36	80.9
November	356.65	18.2	698.00	35.5	18.23	80.3
December	280.92	14.3	576.14	29.3	17.30	76.2

Table 6: Mount Forest Well #5 Flows**Approved Volume (m3/day): 3928****Approved Flow Rate (L/sec): 45.5**

	Avg Daily Volume (m³)	% of Approved Volume	Max Daily Volume (m³)	% of Approved Volume	Peak Flow Rate (L/sec)	% of Approved Flow Rate
January	416.10	10.6	991.71	25.2	41.50	91.2
February	376.36	9.6	626.24	15.9	41.19	90.5
March	458.60	11.7	838.68	21.4	41.37	90.9
April	437.23	11.1	800.00	20.4	41.63	91.5
May	461.00	11.7	860.61	21.9	41.48	91.2
June	667.65	17.0	965.27	24.6	41.56	91.3
July	631.90	16.1	1238.92	31.5	41.13	90.4
August	589.37	15.0	927.61	23.6	41.12	90.4
September	475.65	12.1	899.31	22.9	41.57	91.4
October	495.72	12.6	933.12	23.8	43.40	95.4
November	436.14	11.1	844.76	21.5	39.51	86.8
December	452.76	11.5	761.95	19.4	40.78	89.6

Table 7: Mount Forest Well #6 Flows**Approved Volume (m³/day): 3928****Approved Flow Rate (L/sec): 45.5**

	Avg Daily Volume (m ³)	% of Approved Volume	Max Daily Volume (m ³)	% of Approved Volume	Peak Flow Rate (L/sec)	% of Approved Flow Rate
January	340.18	8.7	598.12	15.2	41.06	90.2
February	349.05	8.9	490.83	12.5	41.22	90.6
March	421.75	10.7	857.29	21.8	40.57	89.2
April	370.76	9.4	722.81	18.4	41.71	91.7
May	473.27	12.0	961.89	24.5	40.47	88.9
June	629.53	16.0	936.15	23.8	42.21	92.8
July	564.98	14.4	1081.27	27.5	44.81	98.5
August	476.79	12.1	806.69	20.5	41.93	92.2
September	493.31	12.6	923.58	23.5	41.90	92.1
October	356.93	9.1	621.58	15.8	41.50	91.2
November	456.24	11.6	651.65	16.6	46.95	103.2*
December	473.70	12.1	812.85	20.7	37.97	83.5

* Flow Rate exceedance occurred on Nov 14, 2025 when operator was on-site completing turbidity sampling.

There was 545,514.72 m³ of water processed in Mount Forest for 2025 (Jan. 01 to Dec. 31). This represents 4.07 % increase compared to the same time period in 2024 and 0.35 % decrease from 2023.

d) Raw and Treated Water Quality

This section describes the water quality monitoring, both regulatory and operational, that has been completed in 2025.

Water Quality Review

Under the SDWA, municipalities are required to monitor both the raw and treated quality of the source water supplied. This monitoring is performed for both regulatory compliance and due diligence and is expected to identify any changes within the treated water as well as in raw source waters.

Table 8: O. Regulation 170/03 Schedule 7-2, Distribution Manual Free Chlorine Residual Summary

Parameter	ODWQS	Total Analyzed	Total Outside ODWQS Criteria	Range	Units
Arthur Free Chlorine Residual	0.05 - 4.0	365	0	0.65 to 1.84	mg/L
Mount Forest Free Chlorine Residual	0.05 - 4.0	365	0	0.65 to 1.81	mg/L

Table 9: O. Regulation 170/03 Schedule 7-3, Raw Turbidity Sampling Summary

Regulation 170/03, Schedule 7-3 requires a minimum of one raw turbidity sample taken monthly from each well that is supplying water to the drinking water system. We typically sample raw turbidity more than once per month but are not required to.

Parameter	ODWQS	Total Analyzed	Total Outside ODWQS Criteria	Range	Units
Arthur Raw Well # 7b	1	49	0	0.15 to 0.60	NTU's
Arthur Raw Well # 8a/b	1	50	0	0.09 to 0.49	NTU's
Mount Forest Raw Well # 3	1	40	0	0.09 to 0.44	NTU's
Mount Forest Raw Well # 4	1	42	0	0.08 to 0.70	NTU's
Mount Forest Raw Well # 5	1	42	0	0.04 to 0.31	NTU's
Mount Forest Raw Well # 6	1	42	0	0.10 to 0.56	NTU's

Note: From May 27th to June 22nd, 2025 Well # 3 was offline due to maintenance.

Table 10: O. Regulation 170/03 Schedule 10-4- Raw Bacteriological Sampling Summary

Parameter	ODWQS	Total Analyzed	Total Outside ODWQS Criteria	Range	Units
Arthur Raw - T.coli	n/a	156	n/a	0	cfu/100mL
Arthur Raw - E.coli	n/a	156	n/a	0	cfu/100mL
Mount Forest Raw - T.coli	n/a	205	n/a	0	cfu/100mL
Mount Forest Raw - E.coli	n/a	205	n/a	0	cfu/100mL

Table 11: O. Regulation 170/03 Schedule 10-3, Treated Bacteriological Sampling Summary

Parameter	ODWQS	Total Analyzed	Total Outside ODWQS Criteria	Range	Units
Arthur Treated - T.coli	0	104	0	0	cfu/100mL
Arthur Treated - E.coli	0	104	0	0	cfu/100mL
Arthur Treated - HPC	n/a	104	n/a	<10-100	cfu/mL
Mount Forest Treated - T.coli	0	205	0	0	cfu/100mL
Mount Forest Treated - E.coli	0	205	0	0	cfu/100mL
Mount Forest Treated - HPC	n/a	205	n/a	<10-720	cfu/mL

* Note: On August 18, 2025, a treated sample at Well # 4 resulted in an HPC of NDOGHPC (No Data: Overgrown with HPC). The following week on August 25, 2025, the same sample location result was <10 cfu/mL HPC.

Table 12: O. Regulation 170/03 Schedule 10-2, Distribution Samples Summary

Parameter	ODWQS	Total Analyzed	Total Outside ODWQS Criteria	Range	Units
Arthur Distribution - T.coli	0	156	0	0	cfu/100mL
Arthur Distribution - E.coli	0	156	0	0	cfu/100mL
Arthur Distribution - HPC	n/a	156	n/a	<10 – 20	cfu/mL
Mount Forest Distribution - T.coli	0	208	0	0	cfu/100mL
Mount Forest Distribution - E.coli	0	208	0	0	cfu/100mL
Mount Forest Distribution - HPC	n/a	208	n/a	<10 – 70	cfu/mL

* Note: On September 29, 2025, a distribution sample at 407 Cork St resulted in an HPC of NDOGHP (No Data: Overgrown with HPC). The following week on October 6, 2025, the same sample location result was <10 cfu/mL HPC.

Treated Water Quality- O. Regulation 170/03 Schedule 13-6, 13-6.1 and 13-7, “Three Month” Sampling Results Summary

In 2025, all operational Treated sources were sampled and analyzed for Schedule 13-6, 13-6.1 and 13-7 parameters as per O.Reg. 170-03.

Regulation 170/03, Schedule 13-6 requires a minimum of one distribution sample taken from the Distribution System where THM’s (trihalomethanes) are most likely to develop (locations with high retention times). The Maximum Allowable Concentration (MAC) for THM’s is 100 ug/L. However, for this parameter the MAC uses a running annual average of quarterly samples.

The results of the running average value for THM’s for all related Distribution System samples in 2025 are below the ½ MAC (half of the maximum allowable concentration). Mount Forest had an annual running average of 20 ug/L of Total THM’s and Arthur had an annual running average of 21.35 ug/L of Total THM’s.

Regulation 170/03, Schedule 13-6.1 requires a minimum of one distribution sample taken from the Distribution System where HAA’s (haloacetic acids) are most likely to develop. On January 1, 2020, the Maximum Allowable Concentration (MAC) for HAA’s of 80 ug/L came into effect. For this parameter, the MAC uses a running annual average of quarterly samples.

The results of HAA’s for all related Distribution System samples in 2025 are below the ½ MAC (half of the maximum allowable concentration). Mount Forest had an annual running average of <5.3 ug/L of HAA’s and Arthur had an annual running average of <5.3 ug/L of HAA’s.

All operational Treated Sources were sampled and analyzed for Nitrates and Nitrites as per Regulation 170/03, Schedule 13-7. There was no instance of any adverse results in 2025.

Table 13: O. Regulation 170/03 Schedule 13-7, Nitrite and Nitrate Sampling Results Summary

Arthur	Date	ODWQS MAC	Well #7b	Well #8a/b
Nitrite (mg/L)	Feb 2025	1	0.003<MDL	0.003<MDL
	May 2025	1	0.003<MDL	0.003<MDL
	Aug 2025	1	0.003<MDL	0.003<MDL
	Nov 2025	1	0.003<MDL	0.003<MDL
Nitrate (mg/L)	Feb 2025	10	0.006<MDL	0.006<MDL
	May 2025	10	0.006	0.006<MDL
	Aug 2025	10	0.006<MDL	0.006<MDL
	Nov 2025	10	0.006<MDL	0.006<MDL

*MDL- method detection limit

Mount Forest	Date	ODWQS MAC	Well #3	Well #4	Well #5	Well #6
Nitrite (mg/L)	Feb 2025	1	0.003<MDL	0.003<MDL	0.003<MDL	0.003<MDL
	May 2025	1	0.003<MDL	0.003<MDL	0.003<MDL	0.003<MDL
	Aug 2025	1	0.003<MDL	0.003<MDL	0.003<MDL	0.003<MDL
	Nov 2025	1	0.003<MDL	0.003<MDL	0.003<MDL	0.003<MDL
Nitrate (mg/L)	Feb 2025	10	0.103	0.006<MDL	2.36	0.006<MDL
	May 2025	10	0.079	0.006<MDL	2.35	0.006<MDL
	Aug 2025	10	0.083	0.006<MDL	2.64	0.006<MDL
	Nov 2025	10	0.078	0.006<MDL	2.43	0.006<MDL

*MDL- method detection limit

Treated Water Quality Statistics- O. Regulation 170/03 Schedule 23 Results Summary

If sampling for a particular schedule's parameters (e.g., Schedule 23 or 24) did not occur within the calendar year of the report, then the most recent values are required to be included in the report for reference.

Table 14: O. Regulation 170/03 Schedule 23 Results Arthur Well #7b

Parameter	Sample Date	Result Value	MAC	Unit of Measure	Exceedance
Antimony	Aug. 19/24	0.6<MDL	6	ug/L	No
Arsenic	Aug. 19/24	3.2	10	ug/L	No
Barium	Aug. 19/24	53.5	1000	ug/L	No
Boron	Aug. 19/24	81	5000	ug/L	No
Cadmium	Aug. 19/24	0.003	5	ug/L	No
Chromium	Aug. 19/24	0.08<MDL	50	ug/L	No
Mercury	Aug. 26/24	0.01	1	ug/L	No
Selenium	Aug. 19/24	0.04<MDL	50	ug/L	No
Uranium	Aug. 19/24	0.226	20	ug/L	No

Table 15: O. Regulation 170/03 Schedule 23 Results Arthur Well #8

Parameter	Sample Date	Result Value	MAC	Unit of Measure	Exceedance
Antimony	Aug. 19/24	0.6<MDL	6	ug/L	No
Arsenic	Aug. 19/24	0.2<MDL	10	ug/L	No
Barium	Aug. 19/24	66.8	1000	ug/L	No
Boron	Aug. 19/24	56	5000	ug/L	No
Cadmium	Aug. 19/24	0.003<MDL	5	ug/L	No
Chromium	Aug. 19/24	0.08<MDL	50	ug/L	No
Mercury	Aug. 19/24	0.01<MDL	1	ug/L	No
Selenium	Aug. 19/24	0.04<MDL	50	ug/L	No
Uranium	Aug. 19/24	0.424	20	ug/L	No

Table 16: O. Regulation 170/03 Schedule 23 Results Mount Forest Well #3

Parameter	Sample Date	Result Value	MAC	Unit of Measure	Exceedance
Antimony	Jan. 13/25	0.6<MDL	6	ug/L	No
Arsenic	Jan. 13/25	1.9	10	ug/L	No
Barium	Jan. 13/25	145	1000	ug/L	No
Boron	Jan. 13/25	31	5000	ug/L	No
Cadmium	Jan. 13/25	<0.003	5	ug/L	No
Chromium	Jan. 13/25	0.16	50	ug/L	No
Mercury	Jan. 13/25	0.01<MDL	1	ug/L	No
Selenium	Jan. 13/25	0.06	50	ug/L	No
Uranium	Jan. 13/25	0.323	20	ug/L	No

Table 17: O. Regulation 170/03 Schedule 23 Results Mount Forest Well #4

Parameter	Sample Date	Result Value	MAC	Unit of Measure	Exceedance
Antimony	Jan. 13/25	0.6<MDL	6	ug/L	No
Arsenic	Jan. 13/25	0.9	10	ug/L	No
Barium	Jan. 13/25	217	1000	ug/L	No
Boron	Jan. 13/25	31	5000	ug/L	No
Cadmium	Jan. 13/25	0.004	5	ug/L	No
Chromium	Jan. 13/25	0.1	50	ug/L	No
Mercury	Jan. 13/25	0.01<MDL	1	ug/L	No
Selenium	Jan. 13/25	0.04<MDL	50	ug/L	No
Uranium	Jan. 13/25	0.203	20	ug/L	No

Table 18: O. Regulation 170/03 Schedule 23 Results Mount Forest Well #5

Parameter	Sample Date	Result Value	MAC	Unit of Measure	Exceedance
Antimony	Jan. 13/25	0.6<MDL	6	ug/L	No
Arsenic	Jan. 13/25	0.2 <MDL	10	ug/L	No
Barium	Jan. 13/25	176	1000	ug/L	No
Boron	Jan. 13/25	30	5000	ug/L	No
Cadmium	Jan. 13/25	0.005	5	ug/L	No
Chromium	Jan. 13/25	0.18	50	ug/L	No
Mercury	Jan. 13/25	0.01 <MDL	1	ug/L	No
Selenium	Jan. 13/25	0.78	50	ug/L	No
Uranium	Jan. 13/25	0.695	20	ug/L	No

Table 19: O. Regulation 170/03 Schedule 23 Results Mount Forest Well #6

Parameter	Sample Date	Result Value	MAC	Unit of Measure	Exceedance
Antimony	Jan. 13/25	0.6<MDL	6	ug/L	No
Arsenic	Jan. 13/25	2.8	10	ug/L	No
Barium	Jan. 13/25	281	1000	ug/L	No
Boron	Jan. 13/25	23	5000	ug/L	No
Cadmium	Jan. 13/25	0.003	5	ug/L	No
Chromium	Jan. 13/25	0.14	50	ug/L	No
Mercury	Jan. 13/25	0.01<MDL	1	ug/L	No
Selenium	Jan. 13/25	0.04<MDL	50	ug/L	No
Uranium	Jan. 13/25	0.114	20	ug/L	No

Treated Water Quality Statistics- O. Regulation 170/03 Schedule 24 Results Summary

If sampling for a particular schedule's parameters (e.g., Schedule 23 or 24) did not occur within the calendar year of the report, then the most recent values are required to be included in the report for reference.

Table 20: O. Regulation 170/03 Schedule 24 Results for Arthur Well #7b

Parameter	Sample Date	Result Value	MAC	Unit of Measure	Exceedance (Yes/No)
Alachlor	Aug. 19/24	0.02<MDL	5	ug/L	No
Atrazine + N-dealkylated metabolites	Aug. 19/24	0.01<MDL	5	ug/L	No
Azinphos-methyl	Aug. 19/24	0.05<MDL	20	ug/L	No
Benzene	Aug. 19/24	0.32<MDL	1	ug/L	No
Benzo(a)pyrene	Aug. 19/24	0.004<MDL	0.01	ug/L	No
Bromoxynil	Aug. 19/24	0.33<MDL	5	ug/L	No
Carbaryl	Aug. 19/24	0.05<MDL	90	ug/L	No
Carbofuran	Aug. 19/24	0.01<MDL	90	ug/L	No
Carbon Tetrachloride	Aug. 19/24	0.17<MDL	2	ug/L	No
Chlorpyrifos	Aug. 19/24	0.02<MDL	90	ug/L	No
Diazinon	Aug. 19/24	0.02<MDL	20	ug/L	No
Dicamba	Aug. 19/24	0.2<MDL	120	ug/L	No
1,2-Dichlorobenzene	Aug. 19/24	0.41<MDL	200	ug/L	No
1,4-Dichlorobenzene	Aug. 19/24	0.36<MDL	5	ug/L	No
1,2-Dichloroethane	Aug. 19/24	0.35<MDL	5	ug/L	No
1,1-Dichloroethylene (vinylidene chloride)	Aug. 19/24	0.33<MDL	14	ug/L	No
Dichloromethane	Aug. 19/24	0.35<MDL	50	ug/L	No
2,4 Dichlorophenol	Aug. 19/24	0.15<MDL	900	ug/L	No
2,4-Dichlorophenoxy acetic acid (2,4 -D)	Aug. 19/24	0.19<MDL	100	ug/L	No
Diclofop-methyl	Aug. 19/24	0.40<MDL	9	ug/L	No
Dimethoate	Aug. 19/24	0.06<MDL	20	ug/L	No
Diquat	Aug. 19/24	1.0<MDL	70	ug/L	No
Diuron	Aug. 19/24	0.03<MDL	150	ug/L	No
Glyphosate	Aug. 19/24	1.0<MDL	280	ug/L	No
Malathion	Aug. 19/24	0.02<MDL	190	ug/L	No
MCPA	Aug. 19/24	0.00012<MDL	0.1	mg/L	No
Metolachlor	Aug. 19/24	0.01<MDL	50	ug/L	No
Metribuzin	Aug. 19/24	0.02<MDL	80	ug/L	No
Monochlorobenzene	Aug. 19/24	0.3<MDL	80	ug/L	No
Paraquat	Aug. 19/24	1.0<MDL	10	ug/L	No
Pentachlorophenol	Aug. 19/24	0.15<MDL	60	ug/L	No
Phorate	Aug. 19/24	0.01<MDL	2	ug/L	No
Picloram	Aug. 19/24	1.0<MDL	190	ug/L	No
Polychlorinated Biphenyls (PCB)	Aug. 19/24	0.04<MDL	3	ug/L	No
Prometryne	Aug. 19/24	0.03<MDL	1	ug/L	No
Simazine	Aug. 19/24	0.01<MDL	10	ug/L	No
Terbufos	Aug. 19/24	0.01<MDL	1	ug/L	No
Tetrachloroethylene	Aug. 19/24	0.35<MDL	10	ug/L	No
2,3,4,6-Tetrachlorophenol	Aug. 19/24	0.20<MDL	100	ug/L	No
Triallate	Aug. 19/24	0.01<MDL	230	ug/L	No
Trichloroethylene	Aug. 19/24	0.44<MDL	5	ug/L	No
2,4,6 - Trichlorophenol	Aug. 19/24	0.25<MDL	5	ug/L	No
Trifuralin	Aug. 19/24	0.02<MDL	45	ug/L	No
Vinyl Chloride	Aug. 19/24	0.17<MDL	1	ug/L	No

Table 21: O. Regulation 170/03 Schedule 24 Results for Arthur Well #8

Parameter	Sample Date	Result Value	MAC	Unit of Measure	Exceedance (Yes/No)
Alachlor	Aug. 19/24	0.02<MDL	5	ug/L	No
Atrazine + N-dealkylated metabolites	Aug. 19/24	0.01<MDL	5	ug/L	No
Azinphos-methyl	Aug. 19/24	0.05<MDL	20	ug/L	No
Benzene	Aug. 19/24	0.32<MDL	1	ug/L	No
Benzo(a)pyrene	Aug. 19/24	0.004<MDL	0.01	ug/L	No
Bromoxynil	Aug. 19/24	0.33<MDL	5	ug/L	No
Carbaryl	Aug. 19/24	0.05<MDL	90	ug/L	No
Carbofuran	Aug. 19/24	0.01<MDL	90	ug/L	No
Carbon Tetrachloride	Aug. 19/24	0.17<MDL	2	ug/L	No
Chlorpyrifos	Aug. 19/24	0.02<MDL	90	ug/L	No
Diazinon	Aug. 19/24	0.02<MDL	20	ug/L	No
Dicamba	Aug. 19/24	0.2<MDL	120	ug/L	No
1,2-Dichlorobenzene	Aug. 19/24	0.41<MDL	200	ug/L	No
1,4-Dichlorobenzene	Aug. 19/24	0.36<MDL	5	ug/L	No
1,2-Dichloroethane	Aug. 19/24	0.35<MDL	5	ug/L	No
1,1-Dichloroethylene (vinylidene chloride)	Aug. 19/24	0.33<MDL	14	ug/L	No
Dichloromethane	Aug. 19/24	0.35<MDL	50	ug/L	No
2,4 Dichlorophenol	Aug. 19/24	0.15<MDL	900	ug/L	No
2,4-Dichlorophenoxy acetic acid (2,4 -D)	Aug. 19/24	0.19<MDL	100	ug/L	No
Diclofop-methyl	Aug. 19/24	0.40<MDL	9	ug/L	No
Dimethoate	Aug. 19/24	0.06<MDL	20	ug/L	No
Diquat	Aug. 19/24	1.0<MDL	70	ug/L	No
Diuron	Aug. 19/24	0.03<MDL	150	ug/L	No
Glyphosate	Aug. 19/24	1.0<MDL	280	ug/L	No
Malathion	Aug. 19/24	0.02<MDL	190	ug/L	No
MCPA	Aug. 19/24	0.00012<MDL	0.1	mg/L	No
Metolachlor	Aug. 19/24	0.01<MDL	50	ug/L	No
Metribuzin	Aug. 19/24	0.02<MDL	80	ug/L	No
Monochlorobenzene	Aug. 19/24	0.3<MDL	80	ug/L	No
Paraquat	Aug. 19/24	1.0<MDL	10	ug/L	No
Pentachlorophenol	Aug. 19/24	0.15<MDL	60	ug/L	No
Phorate	Aug. 19/24	0.01<MDL	2	ug/L	No
Picloram	Aug. 19/24	1.0<MDL	190	ug/L	No
Polychlorinated Biphenyls (PCB)	Aug. 19/24	0.04<MDL	3	ug/L	No
Prometryne	Aug. 19/24	0.03<MDL	1	ug/L	No
Simazine	Aug. 19/24	0.01<MDL	10	ug/L	No
Terbufos	Aug. 19/24	0.01<MDL	1	ug/L	No
Tetrachloroethylene	Aug. 19/24	0.35<MDL	10	ug/L	No
2,3,4,6-Tetrachlorophenol	Aug. 19/24	0.20<MDL	100	ug/L	No
Triallate	Aug. 19/24	0.01<MDL	230	ug/L	No
Trichloroethylene	Aug. 19/24	0.44<MDL	5	ug/L	No
2,4,6 - Trichlorophenol	Aug. 19/24	0.25<MDL	5	ug/L	No
Trifuralin	Aug. 19/24	0.02<MDL	45	ug/L	No
Vinyl Chloride	Aug. 19/24	0.17<MDL	1	ug/L	No

Table 22: O. Regulation 170/03 Schedule 24 Results for Mount Forest Well #3

Parameter	Sample Date	Result Value	MAC	Unit of Measure	Exceedance (Yes/No)
Alachlor	Jan 13/25	0.02<MDL	5	ug/L	No
Atrazine + N-dealkylated metabolites	Jan 13/25	0.01<MDL	5	ug/L	No
Azinphos-methyl	Jan 13/25	0.05<MDL	20	ug/L	No
Benzene	Jan 13/25	0.32<MDL	1	ug/L	No
Benzo(a)pyrene	Jan 13/25	0.004<MDL	0.01	ug/L	No
Bromoxynil	Jan 13/25	0.33<MDL	5	ug/L	No
Carbaryl	Jan 13/25	0.05<MDL	90	ug/L	No
Carbofuran	Jan 13/25	0.01<MDL	90	ug/L	No
Carbon Tetrachloride	Jan 13/25	0.17<MDL	2	ug/L	No
Chlorpyrifos	Jan 13/25	0.02<MDL	90	ug/L	No
Diazinon	Jan 13/25	0.02<MDL	20	ug/L	No
Dicamba	Jan 13/25	0.02<MDL	120	ug/L	No
1,2-Dichlorobenzene	Jan 13/25	0.41<MDL	200	ug/L	No
1,4-Dichlorobenzene	Jan 13/25	0.36<MDL	5	ug/L	No
1,2-Dichloroethane	Jan 13/25	0.35<MDL	5	ug/L	No
1,1-Dichloroethylene (vinylidene chloride)	Jan 13/25	0.33<MDL	14	ug/L	No
Dichloromethane	Jan 13/25	0.35<MDL	50	ug/L	No
2,4 Dichlorophenol	Jan 13/25	0.15<MDL	900	ug/L	No
2,4-Dichlorophenoxy acetic acid (2,4 -D)	Jan 13/25	0.19<MDL	100	ug/L	No
Diclofop-methyl	Jan 13/25	0.40<MDL	9	ug/L	No
Dimethoate	Jan 13/25	0.06<MDL	20	ug/L	No
Diquat	Jan 13/25	1.0<MDL	70	ug/L	No
Diuron	Jan 13/25	0.03<MDL	150	ug/L	No
Glyphosate	Jan 13/25	1.0<MDL	280	ug/L	No
Malathion	Jan 13/25	0.02<MDL	190	ug/L	No
MCPA	Jan 13/25	0.00012<MDL	0.1	mg/L	No
Metolachlor	Jan 13/25	0.01<MDL	50	ug/L	No
Metribuzin	Jan 13/25	0.02<MDL	80	ug/L	No
Monochlorobenzene	Jan 13/25	0.3<MDL	80	ug/L	No
Paraquat	Jan 13/25	1.0<MDL	10	ug/L	No
Pentachlorophenol	Jan 13/25	0.15<MDL	60	ug/L	No
Phorate	Jan 13/25	0.01<MDL	2	ug/L	No
Picloram	Jan 13/25	1.0<MDL	190	ug/L	No
Polychlorinated Biphenyls (PCB)	Jan 13/25	0.04<MDL	3	ug/L	No
Prometryne	Jan 13/25	0.03<MDL	1	ug/L	No
Simazine	Jan 13/25	0.01<MDL	10	ug/L	No
Terbufos	Jan 13/25	0.01<MDL	1	ug/L	No
Tetrachloroethylene	Jan 13/25	0.35<MDL	10	ug/L	No
2,3,4,6-Tetrachlorophenol	Jan 13/25	0.20<MDL	100	ug/L	No
Triallate	Jan 13/25	0.01<MDL	230	ug/L	No
Trichloroethylene	Jan 13/25	0.44<MDL	5	ug/L	No
2,4,6 - Trichlorophenol	Jan 13/25	0.25<MDL	5	ug/L	No
Trifuralin	Jan 13/25	0.02<MDL	45	ug/L	No
Vinyl Chloride	Jan 13/25	0.17<MDL	1	ug/L	No

Table 23: O. Regulation 170/03 Schedule 24 Results for Mount Forest Well #4

Parameter	Sample Date	Result Value	MAC	Unit of Measure	Exceedance (Yes/No)
Alachlor	Jan 13/25	0.02<MDL	5	ug/L	No
Atrazine + N-dealkylated metabolites	Jan 13/25	0.01<MDL	5	ug/L	No
Azinphos-methyl	Jan 13/25	0.05<MDL	20	ug/L	No
Benzene	Jan 13/25	0.32<MDL	1	ug/L	No
Benzo(a)pyrene	Jan 13/25	0.004<MDL	0.01	ug/L	No
Bromoxynil	Jan 13/25	0.33<MDL	5	ug/L	No
Carbaryl	Jan 13/25	0.05<MDL	90	ug/L	No
Carbofuran	Jan 13/25	0.01<MDL	90	ug/L	No
Carbon Tetrachloride	Jan 13/25	0.17<MDL	2	ug/L	No
Chlorpyrifos	Jan 13/25	0.02<MDL	90	ug/L	No
Diazinon	Jan 13/25	0.02<MDL	20	ug/L	No
Dicamba	Jan 13/25	0.02<MDL	120	ug/L	No
1,2-Dichlorobenzene	Jan 13/25	0.41<MDL	200	ug/L	No
1,4-Dichlorobenzene	Jan 13/25	0.36<MDL	5	ug/L	No
1,2-Dichloroethane	Jan 13/25	0.35<MDL	5	ug/L	No
1,1-Dichloroethylene (vinylidene chloride)	Jan 13/25	0.33<MDL	14	ug/L	No
Dichloromethane	Jan 13/25	0.35<MDL	50	ug/L	No
2,4 Dichlorophenol	Jan 13/25	0.15<MDL	900	ug/L	No
2,4-Dichlorophenoxy acetic acid (2,4 -D)	Jan 13/25	0.19<MDL	100	ug/L	No
Diclofop-methyl	Jan 13/25	0.40<MDL	9	ug/L	No
Dimethoate	Jan 13/25	0.06<MDL	20	ug/L	No
Diquat	Jan 13/25	1.0<MDL	70	ug/L	No
Diuron	Jan 13/25	0.03<MDL	150	ug/L	No
Glyphosate	Jan 13/25	1.0<MDL	280	ug/L	No
Malathion	Jan 13/25	0.02<MDL	190	ug/L	No
MCPA	Jan 13/25	0.00012<MDL	0.1	mg/L	No
Metolachlor	Jan 13/25	0.01<MDL	50	ug/L	No
Metribuzin	Jan 13/25	0.02<MDL	80	ug/L	No
Monochlorobenzene	Jan 13/25	0.3<MDL	80	ug/L	No
Paraquat	Jan 13/25	1.0<MDL	10	ug/L	No
Pentachlorophenol	Jan 13/25	0.15<MDL	60	ug/L	No
Phorate	Jan 13/25	0.01<MDL	2	ug/L	No
Picloram	Jan 13/25	1.0<MDL	190	ug/L	No
Polychlorinated Biphenyls (PCB)	Jan 13/25	0.04<MDL	3	ug/L	No
Prometryne	Jan 13/25	0.03<MDL	1	ug/L	No
Simazine	Jan 13/25	0.01<MDL	10	ug/L	No
Terbufos	Jan 13/25	0.01<MDL	1	ug/L	No
Tetrachloroethylene	Jan 13/25	0.35<MDL	10	ug/L	No
2,3,4,6-Tetrachlorophenol	Jan 13/25	0.20<MDL	100	ug/L	No
Triallate	Jan 13/25	0.01<MDL	230	ug/L	No
Trichloroethylene	Jan 13/25	0.44<MDL	5	ug/L	No
2,4,6 - Trichlorophenol	Jan 13/25	0.25<MDL	5	ug/L	No
Trifuralin	Jan 13/25	0.02<MDL	45	ug/L	No
Vinyl Chloride	Jan 13/25	0.17<MDL	1	ug/L	No

Table 24: O. Regulation 170/03 Schedule 24 Results for Mount Forest Well #5

Parameter	Sample Date	Result Value	MAC	Unit of Measure	Exceedance (Yes/No)
Alachlor	Jan 13/25	0.02<MDL	5	ug/L	No
Atrazine + N-dealkylated metabolites	Jan 13/25	0.01<MDL	5	ug/L	No
Azinphos-methyl	Jan 13/25	0.05<MDL	20	ug/L	No
Benzene	Jan 13/25	0.32<MDL	1	ug/L	No
Benzo(a)pyrene	Jan 13/25	0.004<MDL	0.01	ug/L	No
Bromoxynil	Jan 13/25	0.33<MDL	5	ug/L	No
Carbaryl	Jan 13/25	0.05<MDL	90	ug/L	No
Carbofuran	Jan 13/25	0.01<MDL	90	ug/L	No
Carbon Tetrachloride	Jan 13/25	0.17<MDL	2	ug/L	No
Chlorpyrifos	Jan 13/25	0.02<MDL	90	ug/L	No
Diazinon	Jan 13/25	0.02<MDL	20	ug/L	No
Dicamba	Jan 13/25	0.02<MDL	120	ug/L	No
1,2-Dichlorobenzene	Jan 13/25	0.41<MDL	200	ug/L	No
1,4-Dichlorobenzene	Jan 13/25	0.36<MDL	5	ug/L	No
1,2-Dichloroethane	Jan 13/25	0.35<MDL	5	ug/L	No
1,1-Dichloroethylene (vinylidene chloride)	Jan 13/25	0.33<MDL	14	ug/L	No
Dichloromethane	Jan 13/25	0.35<MDL	50	ug/L	No
2,4 Dichlorophenol	Jan 13/25	0.15<MDL	900	ug/L	No
2,4-Dichlorophenoxy acetic acid (2,4 -D)	Jan 13/25	0.19<MDL	100	ug/L	No
Diclofop-methyl	Jan 13/25	0.40<MDL	9	ug/L	No
Dimethoate	Jan 13/25	0.06<MDL	20	ug/L	No
Diquat	Jan 13/25	1.0<MDL	70	ug/L	No
Diuron	Jan 13/25	0.03<MDL	150	ug/L	No
Glyphosate	Jan 13/25	1.0<MDL	280	ug/L	No
Malathion	Jan 13/25	0.02<MDL	190	ug/L	No
MCPA	Jan 13/25	0.00012<MDL	0.1	mg/L	No
Metolachlor	Jan 13/25	0.01<MDL	50	ug/L	No
Metribuzin	Jan 13/25	0.02<MDL	80	ug/L	No
Monochlorobenzene	Jan 13/25	0.3<MDL	80	ug/L	No
Paraquat	Jan 13/25	1.0<MDL	10	ug/L	No
Pentachlorophenol	Jan 13/25	0.15<MDL	60	ug/L	No
Phorate	Jan 13/25	0.01<MDL	2	ug/L	No
Picloram	Jan 13/25	1.0<MDL	190	ug/L	No
Polychlorinated Biphenyls (PCB)	Jan 13/25	0.04<MDL	3	ug/L	No
Prometryne	Jan 13/25	0.03<MDL	1	ug/L	No
Simazine	Jan 13/25	0.01<MDL	10	ug/L	No
Terbufos	Jan 13/25	0.01<MDL	1	ug/L	No
Tetrachloroethylene	Jan 13/25	0.62	10	ug/L	No
2,3,4,6-Tetrachlorophenol	Jan 13/25	0.20<MDL	100	ug/L	No
Triallate	Jan 13/25	0.01<MDL	230	ug/L	No
Trichloroethylene	Jan 13/25	0.44<MDL	5	ug/L	No
2,4,6 - Trichlorophenol	Jan 13/25	0.25<MDL	5	ug/L	No
Trifuralin	Jan 13/25	0.02<MDL	45	ug/L	No
Vinyl Chloride	Jan 13/25	0.17<MDL	1	ug/L	No

Table 25: O. Regulation 170/03 Schedule 24 Results for Mount Forest Well #6

Parameter	Sample Date	Result Value	MAC	Unit of Measure	Exceedance (Yes/No)
Alachlor	Jan 13/25	0.02<MDL	5	ug/L	No
Atrazine + N-dealkylated metabolites	Jan 13/25	0.01<MDL	5	ug/L	No
Azinphos-methyl	Jan 13/25	0.05<MDL	20	ug/L	No
Benzene	Jan 13/25	0.32<MDL	1	ug/L	No
Benzo(a)pyrene	Jan 13/25	0.004<MDL	0.01	ug/L	No
Bromoxynil	Jan 13/25	0.33<MDL	5	ug/L	No
Carbaryl	Jan 13/25	0.05<MDL	90	ug/L	No
Carbofuran	Jan 13/25	0.01<MDL	90	ug/L	No
Carbon Tetrachloride	Jan 13/25	0.17<MDL	2	ug/L	No
Chlorpyrifos	Jan 13/25	0.02<MDL	90	ug/L	No
Diazinon	Jan 13/25	0.02<MDL	20	ug/L	No
Dicamba	Jan 13/25	0.02<MDL	120	ug/L	No
1,2-Dichlorobenzene	Jan 13/25	0.41<MDL	200	ug/L	No
1,4-Dichlorobenzene	Jan 13/25	0.36<MDL	5	ug/L	No
1,2-Dichloroethane	Jan 13/25	0.35<MDL	5	ug/L	No
1,1-Dichloroethylene (vinylidene chloride)	Jan 13/25	0.33<MDL	14	ug/L	No
Dichloromethane	Jan 13/25	0.35<MDL	50	ug/L	No
2,4 Dichlorophenol	Jan 13/25	0.15<MDL	900	ug/L	No
2,4-Dichlorophenoxy acetic acid (2,4 -D)	Jan 13/25	0.19<MDL	100	ug/L	No
Diclofop-methyl	Jan 13/25	0.40<MDL	9	ug/L	No
Dimethoate	Jan 13/25	0.06<MDL	20	ug/L	No
Diquat	Jan 13/25	1.0<MDL	70	ug/L	No
Diuron	Jan 13/25	0.03<MDL	150	ug/L	No
Glyphosate	Jan 13/25	1.0<MDL	280	ug/L	No
Malathion	Jan 13/25	0.02<MDL	190	ug/L	No
MCPA	Jan 13/25	0.00012<MDL	0.1	mg/L	No
Metolachlor	Jan 13/25	0.01<MDL	50	ug/L	No
Metribuzin	Jan 13/25	0.02<MDL	80	ug/L	No
Monochlorobenzene	Jan 13/25	0.3<MDL	80	ug/L	No
Paraquat	Jan 13/25	1.0<MDL	10	ug/L	No
Pentachlorophenol	Jan 13/25	0.15<MDL	60	ug/L	No
Phorate	Jan 13/25	0.01<MDL	2	ug/L	No
Picloram	Jan 13/25	1.0<MDL	190	ug/L	No
Polychlorinated Biphenyls (PCB)	Jan 13/25	0.04<MDL	3	ug/L	No
Prometryne	Jan 13/25	0.03<MDL	1	ug/L	No
Simazine	Jan 13/25	0.01<MDL	10	ug/L	No
Terbufos	Jan 13/25	0.01<MDL	1	ug/L	No
Tetrachloroethylene	Jan 13/25	0.63	10	ug/L	No
2,3,4,6-Tetrachlorophenol	Jan 13/25	0.20<MDL	100	ug/L	No
Triallate	Jan 13/25	0.01<MDL	230	ug/L	No
Trichloroethylene	Jan 13/25	0.44<MDL	5	ug/L	No
2,4,6 - Trichlorophenol	Jan 13/25	0.25<MDL	5	ug/L	No
Trifuralin	Jan 13/25	0.02<MDL	45	ug/L	No
Vinyl Chloride	Jan 13/25	0.17<MDL	1	ug/L	No

Treated Water Quality Statistics- O. Regulations 170/03 Schedule 13-8 and 13-9, “60 Months” Sampling Results Summary

If sampling for a particular schedule’s parameters (e.g., Schedule 23 or 24) did not occur within the calendar year of the report, then the most recent values are required to be included in the report for reference.

Fluoride and Sodium are sampled on the “60 Months” sampling schedule. Results for most recent tests can be found in Table 26.

Table 26: O. Regulation 170/03 Schedule 13-8 and 13-9, Fluoride and Sodium Results

Parameter/Location	Sample Date	Result Value	Unit of Measure	Exceedance
Sodium- Arthur Well #7b	Sep. 11/23	36.6	mg/L	Yes ¹
Sodium- Arthur Well #8	Sep. 11/23	21.5	mg/L	Yes ¹
Sodium- Mount Forest Well #3	Sep. 11/23	21.9	mg/L	Yes ¹
Sodium- Mount Forest Well #4	Sep. 11/23	12.3	mg/L	No
Sodium- Mount Forest Well #5	Sep. 11/23	68.8	mg/L	Yes ¹
Sodium- Mount Forest Well #6	Sep. 11/23	10.4	mg/L	No
Fluoride- Arthur Well #7b	Sep. 11/23	1.32	mg/L	No
Fluoride-Arthur Well #8	Sep. 11/23	0.35	mg/L	No
Fluoride-Mount Forest Well #3	Sep. 11/23	0.98	mg/L	No
Fluoride-Mount Forest Well #4	Sep. 11/23	0.59	mg/L	No
Fluoride-Mount Forest Well #5	Sep. 11/23	0.17	mg/L	No
Fluoride-Mount Forest Well #6	Sep. 11/23	0.78	mg/L	No

¹ The aesthetic objective for sodium in drinking water is 200 mg/L. The local Medical Officer of Health should be notified when the sodium concentration exceeds 20 mg/L so that this information may be communicated to local physicians for their use with patients on sodium restricted diets.

Treated Water Quality Statistics- O. Regulations 170/03 Schedule 15.1 Sampling Results Summary

If sampling for a particular schedule’s parameters (e.g., Schedule 23 or 24) did not occur within the calendar year of the report, then the most recent values are required to be included in the report for reference.

The Mount Forest and Arthur Drinking Water Systems are under reduced sampling under Schedule 15.1 which means we are not required to sample plumbing but are still required to sample in the distribution system. Results for most recent tests can be found in Table 27.

Table 27: O. Regulation 170/03 Schedule 15.1, Lead, Alkalinity and pH Results

Parameter/Location	Sample Date	Result Value	MAC	Unit of Measure	Exceedance
Lead – Hydrant # 125 James St.	Jan 22/24	0.05	10	ug/L	No
Lead – Hydrant # 32 Queen St. West	Jan 22/24	0.03	10	ug/L	No
Lead – Hydrant # 24 Elgin St. South	Jan 22/24	0.07	10	ug/L	No
Lead – Hydrant # 95 Francis St.	Jan 22/24	0.01	10	ug/L	No
Lead – Tucker/Eliza St. Blow Off	Jan 22/24	0.05	10	ug/L	No
Alkalinity – Hydrant # 125 James St.	Jan 13/25	246	30-500	mg/L	No
Alkalinity – Hydrant # 32 Queen St.	Jan 13/25	235	30-500	mg/L	No
Alkalinity – Hydrant # 24 Elgin St.	Jan 13/25	232	30-500	mg/L	No
Alkalinity – Hydrant # 95 Francis St.	Jan 13/25	208	30-500	mg/L	No
Alkalinity – Tucker/Eliza St. Blow Off	Jan 13/25	207	30-500	mg/L	No
Field pH – Hydrant # 125 James St.	Jan 13/25	7.16	-	-	No
Field pH – Hydrant # 32 Queen St	Jan 13/25	7.2	-	-	No
Field pH – Hydrant # 24 Elgin St. South	Jan 13/25	7.4	-	-	No
Field pH – Hydrant # 95 Francis St.	Jan 13/25	6.7	-	-	No
Field pH – Tucker/Eliza St. Blow Off	Jan 13/25	7.2	-	-	No
Lead – Hydrant # 125 James St.	Jul 22/24	0.05	10	ug/L	No
Lead – Hydrant # 32 Queen St. West	Jul 22/24	0.08	10	ug/L	No
Lead – Hydrant # 24 Elgin St. South	Jul 22/24	0.06	10	ug/L	No
Lead – Hydrant # 95 Francis St	Jul 22/24	0.01	10	ug/L	No
Lead – Tucker/Eliza St. Blow Off	Jul 22/24	0.08	10	ug/L	No
Alkalinity – Hydrant # 125 James St.	Jul 14/25	250	30-500	mg/L	No
Alkalinity – Hydrant # 32 Queen St.	Jul 14/25	234	30-500	mg/L	No
Alkalinity – Hydrant # 24 Elgin St.	Jul 14/25	282	30-500	mg/L	No
Alkalinity – Hydrant # 95 Francis St.	Jul 14/25	214	30-500	mg/L	No
Alkalinity – Tucker/Eliza St. Blow Off	Jul 14/25	211	30-500	mg/L	No
Field pH – Hydrant # 125 James St.	Jul 14/25	7.3	-	-	No
Field pH – Hydrant # 32 Queen St.	Jul 14/25	7.37	-	-	No
Field pH – Hydrant # 32 24 Elgin St.	Jul 14/25	7.2	-	-	No
Field pH – Hydrant # 95 Francis St.	Jul 14/25	6.56	-	-	No
Field pH – Tucker/Eliza St. Blow Off	Jul 14/25	7.01	-	-	No

e) Significant Expenses Incurred

The table below outlines a brief description and breakdown for significant monetary expenses occurred in 2025.

Location	Maintenance Item	Cost
Arthur	Well 8A Maintenance/Inspection	\$ 24,696.15
Arthur	Well 8 Roof	\$ 2,747.52
Mount Forest	John St, Waterloo St - Queen St W – Water Portion	\$ 179,148.00
Mount Forest	Main Street Resurfacing Project – Water Portion	\$ 176,300.00
Mount Forest	Well 3 Liner Installation	\$ 112,798.22
Mount Forest	Leak Detection	\$ 3,663.36
Arthur	Arthur Water Supply/Storage EA (ongoing)	\$ 7,344.73
Arthur/Mount Forest	Watermain Valve and Fire Hydrant Replacement	\$ 7,193.45
Arthur/Mount Forest	Automatic Gates at Facilities	\$ 97,338.20
Arthur/Mount Forest	Rate Study and Financial Plan – Water Portion	\$12,656.40
Arthur/Mount Forest	Master Plan Technical Update (ongoing)	\$ 96,174.21
Arthur/Mount Forest	SCADA Historian Server Upgrade	\$ 26,276.27
Arthur	Multi-Leg Water Tower Interior Cleaning and Inspection	\$ 4,606.67

f) Source Water Protection

For reporting purposes, the Township of Wellington North is subject to two Source Protection Plans (based on watershed or Conservation Authority boundaries): Grand River Plan and the Saugeen Valley, Grey Sauble, Northern Bruce Peninsula Plan (Saugeen Valley). Although the Ausable Bayfield Maitland Valley (ABMV – Maitland Valley) Plan also encompasses part of the municipality, there are no reporting requirements associated with that Plan for the Township. In 2025, all Source Protection Plans were in effect.

Under Section 81 of the Clean Water Act and Section 65 of O. Reg. 287/07, an annual report must be prepared by a Risk Management Official and submitted to the appropriate Source Protection Authority (Conservation Authority) by February 1st of each year. Under Section 45 of the *Clean Water Act*, a public body, including a municipality, must comply with monitoring and reporting policies designated by a Source Protection Plan. The Township of Wellington North Risk Management Official and Municipal Annual Reports were prepared and submitted to the appropriate authorities by February 1, 2026.

Summary of Key Aspects

The Wellington County municipalities continue to implement source protection under the Wellington Source Water Protection partnership, www.wellingtonwater.ca. In the reporting year, progress continued in the implementation of source protection in the municipality. A summary of key aspects of the Risk Management Official Report and Municipal Report are provided below.

This year, there were 39 development applications reviewed and staff comments provided on applications within municipal wellhead protection areas. There was one notice issued per Section 59 of the Clean Water Act within the municipality. There were 533 development applications (notices and comments) reviewed County wide in 2025. This included 70 Section 59 notices issued and staff comments on 463 additional development applications, County wide. This includes 144 comment memos including 67 requests for drinking water threat disclosure reports and / or management plans. The number of development applications reviewed within the Township is in line with the five year average of 38. There was a County wide increase in the total number of development applications reviewed from the five-year average of 436. The review of development applications within wellhead protection areas is a key component of implementing the Clean Water Act as this ensures the municipality is in compliance with requirements relating to future activities that may pose a risk to municipal drinking water. In addition to the notices and comments provided, other applications were screened out by building or planning staff following Risk Management Official Written Direction provided by Wellington Source Water Protection.

Analysis continued on the threat verification data collected in previous years on residential, agricultural, industrial, commercial and institutional activities identified as potential significant drinking water threats in the approved Assessment Reports. Staff complete a variety of tasks to remove or confirm and then mitigate activities identified as potential significant drinking water threats in the approved Assessment Reports. These threat activities are existing and the analysis can involve desk top interpretation of air photos or GIS data, phone calls, review of municipal records, windshield surveys, site inspections by Risk Management staff and if confirmed, then mitigation through septic inspection, prohibition and / or negotiation of risk management plans. As a result of this analysis, staff currently estimate approximately 13% of threat activities (16 properties) in the municipality still require action to either remove or confirm / mitigate the threat activities while 87% have been either removed or confirmed and mitigated. Note that the percentages are weighted equally between Source Protection Authorities to provide an overall municipal percentage. All of the remaining threat activities are winter maintenance or fuel handling / storage activities and are located within the Mount Forest wellhead protection areas. The deadline to have these activities verified and risk management plans in place, if necessary, is 2027.

To determine compliance with Clean Water Act requirements, 50 inspections were conducted in the Township with 36 being for compliance purposes (prohibition) with no contraventions found. Fourteen inspections were conducted for threat verification purposes, primarily to confirm winter maintenance activities and whether Risk Management Plans will be required. Three inspections were conducted for Risk Management Plan compliance purposes on two properties. These inspections were related to winter maintenance activities and contraventions were noted. Inspectors followed up with the property owners to address the contraventions.

One Risk Management Plan was amended, one Risk Management Plan was ordered into place and one Risk Management Plan was revoked in the reporting year. This brings the total number of cumulative Risk Management Plans within the Township to 17. As reported to Council previously, one Risk

Management Plan had been under negotiation for fuel handling / storage with the corporate office of a petroleum company for multiple years. Due to the time elapsed during negotiations and the fact the Source Protection Plan deadline had passed, this Risk Management Plan was ordered into place in 2025. The amended Risk Management Plan was related to an expiry of the previous plan and the revoked Risk Management Plan was due to a store closure. The remaining 16 winter maintenance properties requiring Risk Management Plans have a current deadline of 2027. Negotiations related to these Risk Management Plans were on hold in 2024 and 2025 due to an update required in the Saugeen Valley Assessment Report mapping that required Provincial approval. This approval was granted in October 2025. Staff will now restart negotiations for these properties.

The following is a summary of the Education and Outreach results, County wide, for 2025. In total, 45 education and outreach daily events were completed this reporting year. Seven of the events were internal training sessions for municipal staff on general source protection topics and more detailed training on how it relates to municipal planning and building. Six of the events were external training sessions or conferences including training other Risk Management Officials / Inspectors in the Province and industry groups such as property managers. Eighteen events supported a variety of community events including Fall Fairs, farm and home shows including the Arthur Fall Fair. There were fourteen school events including classroom visits, participation in Palmerston Agricultural Awareness Day and Grand River Agricultural Society's Pizza Perfect and the annual Children's Groundwater Festival.

School programming included elementary, Grade 8 and college students and included a Grade 8 classroom visit in Arthur. Wellington Source Water Protection / County of Wellington is a sponsor for the Waterloo-Wellington Children's Groundwater Festival. The Festival ran for 5 days plus a sixth day as a virtual Festival. Links to the virtual Festival content are available here <https://www.youtube.com/@watereducation4640>. The Children's Groundwater Festival is an excellent way to reach Grade 2 to 5 and high school children (and their parents) and deliver water protection messages including source protection. Registration for both virtual and in-person Festival was over 6,500 students, parents and teachers with many County and Township schools participating. Staff continue to participate on the organizing committee and various sub-committees including serving as co-chairs.

In addition to events, development reviews and inspections continued and included educational material being provided directly to the proponents generally regarding the threats present, the process (development review, RMP negotiations, prohibition etc.), property specific mapping, and general Source Water information. Where necessary, stickers and metal tags were provided to proponents listing the Spills Action Centre number and that their location is located within a vulnerable area for municipal wells. Proactive drop off of materials to businesses within wellhead protection areas occurred this year. Updates were made to the Wellington Source Water Protection website www.wellingtonwater.ca, and staff continue to update and maintain ten fact sheets on specific topics and other print media (i.e. post cards to direct applicants to mapping). Throughout the year, social media posts on a variety of topics were either posted or re-shared by our municipalities' corporate channels. Often the content of these posts was from the Conservation Ontario social media calendar or

in partnership with the local Conservation Authorities. Four newspaper ads were also run during the year.

In 2025, both Source Protection Plans in the Township were undergoing amendment. Staff reviewed, provided comments and in some cases assisted Conservation Authority staff in authoring portions of the various amendments. Specifically, staff were heavily involved in authoring policy amendments for the Grand River Source Protection Plan. This is a provincial requirement under Section 36 of the Clean Water Act and involved review of all Grand River Source Protection Plan policies applicable within the County and, where necessary, amendments. The work is required to bring the Wellington County Chapter of the Grand River Source Protection Plan in compliance with the Provincial 2021 Director's Technical Rules. Staff also provided support related to mapping amendments required to the Saugeen Valley Assessment Report and to a County's Official Plan amendment that updated the wellhead protection area mapping. The Grand River amendment was provided to the Province for early engagement review in 2025 while the Saugeen Valley amendment received Minister approval and came into legal effect in October 2025. The County's Official Plan amendment (OPA 126) also received Provincial approval and came into legal effect in 2025.

In the reporting year, there are a number of water supply and / or water supply master plan projects related to water systems within or adjacent to the County. In the Township, staff provided support to the Class Environmental Assessment for the new Arthur supply well including authoring the source protection considerations for that study. With provincial funding, a joint groundwater modelling project began in 2025 in partnership with the Town of Minto and Township of Mapleton with a Request for Proposal closing this year. This project will update wellhead protection areas in all three of the northern Wellington County municipalities and was procured by the Township on behalf of the other municipalities. The successful consultant, AECOM, began work in November 2025. Staff also continued to provide support for the implementation of the municipal Consolidated Linear Environmental Compliance Approval for both wastewater and stormwater. There are annual assessments required for both approvals that assess source water protection implications and requirements for wastewater and / or stormwater projects within wellhead protection areas. These assessments are required every 12 months and Source Protection staff completed both assessments in 2025 as required. The septic inspection program occurs on a five-year cycle. The most recent round of septic inspections was completed in the Township in 2023. No septic inspections were required in 2025.

For further information, please contact Kyle Davis, Risk Management Official, 519-846-9691 ext 362 or kdavis@centrewellington.ca

Note: The Source Water Protection information in this report was provided by Kyle Davis, Risk Management Official.